

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140176, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Friday, March 21, 2014

**Comments: NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT & BOXES
MATERIAL & WORKMANSHIP FROM CASH WRAP TO COLUMN @ LH/L.5. G.C. AND E.C.
TO ENSURE LAYOUT IS CORRECT. OK TO COVER WHEN READY**