

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, March 24, 2014

Partial Correction
1 MISC

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #1-11; **[12; 13; 14 IFF CAGES ARE RAISED BEFORE POUR TO PROVIDE >=3" CLEARANCE BELOW RODS]**

Partial Correction
2 MISC

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL AT FOLLOWING LOCATIONS: FROM LP#8 ~ 75 LF NE; FROM LP #1 TO #2; FROM LP #4 WEST 66'; FROM #4 TO #5; FROM #4 TO QUAZITE BOX 15' WEST; FROM #3 TO 80' N/NE;

Comments: