

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132180, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, March 25, 2014

Partial Correction
1 MISC

OK TO COVER WHEN READY COMPONENTS OF RATED MECHANICAL SHAFTS:
SHAFT AT B'.2/18.5: "T" CROSS FRAMING & SHAFT LINER BOARD; "T" STEM
FRAMING W & N WALLS FRAMING & SHAFT LINER BOARD; SHAFT AT
B'.5/17.9 W & S WALLS FRAMING & SHAFT LINER BOARD; SHAFT AT B'.2/17.1
FRAMING & SHAFT LINER BOARD;

Partial Correction
2 MISC

GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN
READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: SPACE
136 S WALL 4' TOP-OUT; 143 S WALL; [137; 139; 141; 208; CORR CROSS-WALL
@ DOOR A203; [COMMON WALL @ 056/057; ABOVE DOOR OPNG #203; 123
W,N,E WALLS; 124, 136 & 153 BOTH FACES; [RATED WALL CLOSED TO
COLUMN AND FIRE-SEALED @ B'/12.8; E-W WALL ADJACENT TO (7) FROM (A)
TO (A.8); COMMON WALL BETWEEN 115A & 116; **RT 5A117 S WALL BOTH
FACES OK TO TAPE, MUD & FIRE-SEAL;**

Comments: