



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20122453	Date:	March 25, 2014
Project Title:	JOHN CALVIN MANOR	Applicant:	
Location:	310 NW MURRAY RD, LEES SUMMIT, MO 64081	EAGLE ONE SECURITY, INC	
Type of Work:		P.O. BOX 981	
Occupancy Group:	R-2	BLUE SPRINGS, MO 64013	
Description:	INTERIOR REMODEL	Primary:	<NO PRIMARY PHONE>
Construction Type:	Type VB (Unprotected)		
Map Page:	195E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 907.2 Where required—new buildings and structures.

An approved manual, automatic or manual and automatic fire alarm system installed in accordance with the provisions of this code and NFPA 72 shall be provided in new buildings and structures in accordance with Sections 907.2.1 through 907.2.23 and provide occupant notification in accordance with Section 907.10, unless other requirements are provided by another section of this code. Where automatic sprinkler protection installed in accordance with Section 903.3.1.1 or 903.3.1.2 is provided and connected to the building fire alarm system, automatic heat detection required by this section shall not be required.

The automatic fire detectors shall be smoke detectors. Where ambient conditions prohibit installation of automatic smoke detection, other automatic fire detection shall be allowed.

Change the heat detectors to smoke detectors

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.