

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, March 26, 2014

Partial Correction
2 MISC

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL AT FOLLOWING LOCATIONS: FROM LP#8 ~ 75 LF NE; FROM LP #1 TO #2; FROM LP #4 WEST 66'; FROM #4 TO #5; FROM #4 TO QUAZITE BOX 15' WEST; FROM #3 TO 80' N/NE; FROM #3 TO #4; FROM #5 TO 180 LF WEST; PARTIAL AT BOLLARDS AT EAST FRONT OF BUILDING; GIVEN DECISION TO UTILIZE METALLIC CONDUIT, PER NEC, COMPLIANT COVER CONSISTS OF 2" CONCRETE + EARTH BACKFILL WITH CONDUIT AT 6" BELOW GRADE

Comments: REVISED ELECTRICAL SITE PLAN IS NOT KNOWN TO HAVE BEEN SUBMITTED. OBTAIN APPROVAL BEFORE NEXT UNDERGROUND ELECTRICAL INSPECTION REQUEST.