

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, March 27, 2014

Partial Correction
1 MISC

-AREAS APPROVED TO COVER EXCEPT THE FOLLOWING:
-INSTALL LONG SWEEP OR APPROVED FITTING AT SE WASTE STACK
CONNECTION TO BUILDING DRAIN

Comments: