

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Thursday, March 27, 2014

Partial Correction

1 MISC

FOLLOWING AREA(S) OK FOR USE & OCCUPANCY: AREA "B";

Corrective Action Required

3 MISC

ELECTRICAL RECEPTACLE AT RTU2 NOT HOT FOR TEST. MUST BE TESTED FOR GFCI PROTECTION.

Corrective Action Required

12 MISC

RESOLVE ANY FIRE DEPARTMENT ISSUES

Corrective Action Required

15 MISC

RESOLVE ANY PLANNING DEPARTMENT ISSUES

Corrective Action Required

16 MISC

WHEN EXTERIOR AND SITE WORK IS COMPLETED REQUEST FURTHER INSPECTION. NOTE SOME DOWNSPOUTS ARE NOT IN PLACE. ENSURE ALL ARE FULLY ATTACHED TO BUILDING.

Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, March 27, 2014
---	------------	---------	--------------------------

Partial Correction

1 MISC

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL AT FOLLOWING LOCATIONS: FROM LP#8 ~ 75 LF NE; FROM LP #1 TO #2; FROM LP #4 WEST 66'; FROM #4 TO #5; FROM #4 TO QUAZITE BOX 15' WEST; FROM #3 TO 80' N/NE; FROM #3 TO #4; FROM #5 TO 180 LF WEST; **AT BOLLARDS AT EAST FRONT OF BUILDING MINIMUM 6" DEPTH APPROVED BASED ON "GENERAL" LINE IN NEC TABLE 300.5**

Comments: