

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, March 31, 2014
Partial Correction 1 MISC		OK FOR TOP-OUT AT FIRE COMMAND B107; GWB AT FIRE COMMAND VESTIBULE @ 5TH FLOOR OK TO TAPE, MUD AND FIRE-CAULK	
<b>In-wall Inspection</b>	John Borns	Partial	Monday, March 31, 2014
Partial Correction 1 MISC		OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT FIRE COMMAND B107	

**Comments:**