



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20140176	Date:	March 31, 2014
Project Title:	CHARLOTTE RUSSE	Applicant:	
Location:	880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086	ABSOLUTE FIRE INC 5899 RAYTOWN ROAD RAYTOWN, MO 64133--3384	
Type of Work:		Primary: (816) 737-9991	
Occupancy Group:	M		
Description:	TENANT FINISH FOR CLOTHING STORE		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Flow/control valves needs to be properly addressed at the panel for the address of the business
2. Control valves are to be marked for identification

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.