

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20130856, Building Permit - Residential
Address: 200 SW JEFFERSON ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Mechanical Inspection - Residential	John Borns	Passed	Tuesday, April 01, 2014

Corrective Action Required

1	MISC	NEC 330.30: NON-METALLIC ELECTRICAL WHIP NOT SECURED TO WALL WITHIN 12" OF ENTRY TO A/C CONDENSER DISCONNECT ENCLOSURE.
---	------	--

Comments: APPROVED. CLOSE PERMIT