

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, April 01, 2014

Partial Correction
1 MISC

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL AT FOLLOWING LOCATIONS: FROM LP#8 ~ 75 LF NE; FROM LP #1 TO #2; FROM LP #4 WEST 66'; FROM #4 TO #5; FROM #4 TO QUAZITE BOX 15' WEST; FROM #3 TO 80' N/NE; FROM #3 TO #4; FROM #5 TO 180 LF WEST; AT BOLLARDS AT EAST FRONT OF BUILDING MINIMUM 6" DEPTH APPROVED BASED ON "GENERAL" LINE IN NEC TABLE 300.5; **1" PVC CONDUITS TRENCHED FROM [A] TO [B] TO [C] AS MARKED ON SITE ELECTRICAL PERMIT PRINT;**

Comments: