

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, April 01, 2014

Partial Correction
1 MISC

OK FOR TOP-OUT AT FIRE COMMAND B107; 2ND LAYER GWB AT FIRE
COMMAND VESTIBULE @ 5TH FLOOR OK TO TAPE, MUD AND FIRE-CAULK

Comments: