

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, April 02, 2014

Partial Correction  
1 MISC

OK TO TAPE, MUD AND FIRE-CAULK: 2ND LAYER 5/8" TYPE X GWB AT FIRE COMMAND VESTIBULE @ 5TH FLOOR;

**ONE LAYER 5/8" TYPE X GWB TOP-OUT @ FIRE COMMAND B107: NORTH & EAST WALLS BOTH FACES; SOUTH WALL SOUTH FACE**

Comments: