

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132462, Building Permit - Commercial
Address: 2000 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mike Copeland Codes Commercial		Partial	Thursday, April 03, 2014

Corrective Action Required

1	MISC	-SUBMIT MED GAS TEST RESULTS -TEST EMERGENCY GENERATOR BACKUP ON RECEPTACLES
		OKAY TO STORE FIXTURES

Comments: