

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Friday, April 04, 2014
Partial Correction 1 MISC		CHEF'S OFFICE AND DIETARY ROOM, SCREW PATTERN APPROVED SEAL ALL THROUGH PENETRATIONS	
In-wall Inspection	Mike Copeland	Partial	Friday, April 04, 2014
Partial Correction 1 MISC		-APPROVED TO COVER THE FOLLOWING WITH 1ST LAYER PENDING SUCCESSFUL REVIEW: CHEF'S OFFICE, DIETARY OFFICE WALLS OKAY TO COVER WEST WALL IN DRY STORAGE	

Comments: