

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, April 08, 2014

Partial Correction
1 MISC

1A029A & 1A029B CHEF'S OFFICE AND DIETARY ROOM: AT E WALL ONE LAYER 5/8" TYPE X GWB TO STRUCURAL DECK TAPED, MUDDED AND FIRE-SEALED; AT N, W, S WALLS ONE LAYER 5/8" TYPE X GWB TO LID ELEVATION PER PR#1 OK TO TAPE, MUD, AND FIRE-SEAL

1A029 STORAGE: AT N & NE WALLS FRAMING AND LINER BOARD OK TO BE COVERED WHEN READY

Comments: