

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20131169, Building Permit - Residential

Address: 600 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:C, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Not Ready	Wednesday, April 09, 2014

Partial Correction

1 MISC

FIRE/SECURITY SYSTEM SET-UP AND TESTING IS RESPONSIBILITY OF GENERAL CONTRACTOR AND JKV BY SPECIALTY CONTRACTOR.

Partial Correction

2 MISC

FOLLOWING UNITS OK FOR OCCUPANCY: UNIT A; **UNIT B AFTER ELECT RECPT AT CLOTHES DRYER IS INSTALLED;**

CONTINGENT ON:

- FINISH SITEWORK TO BE COMPLETED
- EROSION CONTROL TO BE MAINTAINED AND STREET TO BE KEPT CONSTRUCTION CLEAN

Comments: