

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20122456, Building Permit - Commercial  
Address: 1611 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Wednesday, April 09, 2014

Partial Correction  
1 MISC

BUILDING 4: OK TO COVER WALL & CEILING FRAMING AND CONCEALED SYSTEMS AT: UNITS 400-407; **408-415 AFTER LOOSE EXISTING BOXES ARE FULLY SECURED TO STUDS;**

**WIRING AT ALL ELECTRICAL BOXES TO BE APPROVED BEFORE DEVICES ARE INSTALLED. ENSURE ALL METALLIC BOXES ARE BONDED AND EQUIPMENT GROUNDING CONDUCTORS ARE CONNECTED WITH WIRE NUTS OR CRIMP CONNECTORS.**

Comments: