

Temporary Certificate of Occupancy

Permit #: PRCOM20132712
Address: 208 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Thursday, April 10, 2014
Inspected By: John BornsJohn BornsJoe Dir
Expiration Date: 4/24/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, April 10, 2014
Above Ceiling Inspection	John Borns	Passed	Thursday, April 10, 2014
Occupancy Inspection - Fire	Joe Dir	Passed	Thursday, April 10, 2014

Call for inspection when rear corridor floor is uniformly leveled to comply with ANSI maximum elevation changes. Also, at 210 back room finish floor channel pour-back level with existing floor surface + use non-protruding plug at cleanout.