

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20132130, Building Permit - Commercial  
Address: 1702 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	John Borns	Passed	Friday, April 11, 2014

**Comments: INSTALLATION OF 20A CIRCUIT APPROVED AFTER J.B. ABOVE PANEL IS SECURED TO STRUCTURE AND MC CABLE IS SECURED TO STRUCTURE WITHIN 12" OF ENTRY TO BOX. CLOSE PERMIT.**