

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, April 11, 2014
Partial Correction 1 MISC		1A029A & 1A029B CHEF'S OFFICE AND DIETARY ROOM: AT E WALL ONE LAYER 5/8" TYPE X GWB TO STRUCURAL DECK TAPED, MUDDDED AND FIRE-SEALED; AT N, W, S WALLS ONE LAYER 5/8" TYPE X GWB TO LID ELEVATION PER PR#1 OK TO TAPE, MUD, AND FIRE-SEAL	
Partial Correction 2 MISC		1A029 DRY STORAGE: ALL PERIMETER WALLS BOTH FACES PER REV. 1 ONE LAYER 5/8" TYPE X GWB OK TO TAPE, MUD & FIRE-SEAL	
In-wall Inspection	John Borns	Partial	Friday, April 11, 2014
Partial Correction 1 MISC		OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT: CHEF'S OFFICE; DIETARY OFFICE; WEST WALL IN DRY STORAGE; WALL TO STRUCTURAL DECK ABOVE DOOR (1A029B);	

Comments: