



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

April 11, 2014

REORGANIZED SCHOOL DIST NO 7
600 SE MILLER
LEES SUMMIT, MO 64063--4297

Permit No: PRCOM20140591
Project Title: LSR7 STANSBERYY LEADERSHIP CENTER BUILDING SECURITY UPGRADES
Project Address: 301 NE TUDOR RD, LEES SUMMIT, MO 64086
Parcel Number: 52900043500000000
Location: LEES SUMMIT HIGH SCHOOL ON DOUGLAS STREET PT LOT 1 DAF: BEG NW COR SD LOT 1 TH S 87 DEG E 1485' MOL TH S 1 DEG W 1520' MOL TH N 87 DEG W 1494.41' TH N 1 DEG E 1032.45' TH N 1 DEG E 479.98' TO POB
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: EDUCATIONAL
Description: BUILDING SECURITY UPGRADES

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. Extend sprinkler coverage to include vestibule. Submit as-built drawings for the additional sprinkler coverage
2. Extend the emergency egress lighting for the exterior of the vestibule

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.