

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122456, Building Permit - Commercial
Address: 1611 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rough Electrical Inspection - Commercial | John Borns | Partial | Friday, April 11, 2014 |

Partial Correction
1 MISC

**EQUIPMENT GROUND CONTINUITY AND GROUNDING OF METALLIC BOXES
APPROVED FROM 400 THRU 407;**

Comments: