

## **PLAN REVIEW CONDITIONS**

April 14, 2014

CORTLAND MORGAN  
711 NORTH FIELDER ROAD  
ARLINGTON, TX 76012-

Permit No: PRCOM20140543  
Project Title: RUE 21 SUMMIT FAIR  
Project Address: 950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086  
Parcel Number: 51700033300000000  
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A  
Type of Work: NEW TENANT FINISH  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH

### ***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of MEP contractors.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

1. 2012 IPC Location of shutoff valves. Shutoff valves shall be installed in the following locations:

1. On the fixture supply to each plumbing fixture other than bathtubs and showers in one- and two-family residential occupancies, and other than in individual sleeping units that are provided with unit shutoff valves in hotels, motels, boarding houses and similar occupancies.
2. On the water supply pipe to each sillcock.
3. On the water supply pipe to each appliance or mechanical equipment.

Action required: Comment for informational purposes. Provide shutoff valves at required locations. To be verified at inspection.

2. Planning & Development sign requirements as concerns the proposed vinyl signage in storefront windows.

- Summit Fair Shopping Center has a Tenant Sign Criteria Handbook that was approved by City Council.
- The handbook states the following for window signs: Decals and lettering or other signing indicating product lines or credit card acceptability shall not be permitted on the storefront glazing other than store operating hours.
- If signs are applied internally, the City doesn't regulate this type of sign application.
- If the window sign is applied to the exterior, than the City would have to review (which the handbook would dictate that it's not allowed).

Authorization from RED Development would be required for this type of sign application. If RED is okay with it and if the sign is applied internally than the City would be okay with the application.

Required actions: Coordinate signage with RED Development. If signage is proposed to be applied to exterior of windows, contact Jennifer Thompson with our Planning Department at 969-1606.

#### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing on doors leading into space, front door and corridor door. Verified at inspection

2. 907.12 Duct smoke detectors.

Duct smoke detectors shall be connected to the building's fire alarm control panel when a fire alarm system is provided. Activation of a duct smoke detector shall initiate a visible and audible supervisory signal at a constantly attended location. Duct smoke detectors shall not be used as a substitute for required open area detection.

Duct detection required for units over 2,000 cfm. Show on alarm plans

3. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans for approval

4. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans for approval

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***

