

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140176, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Failed	Wednesday, April 16, 2014

Corrective Action Required

1 MISC

#6 ISOLATED GROUND CONDUCTOR FROM TRANSFORMER TO PANEL "B" PER NOTE [8] ON SHEET E-4 NOT FOUND INSTALLED. AFFIX PERMANENT LABEL "C" ON SERVICE METER ENCLOSURE.

Comments: