

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, April 16, 2014
Partial Correction 2 MISC		5/8" TYPE X GWB INSTALLED AND FIRE-SEALED AT CORRIDOR FACE OF SOUTH WALL OF FIRE COMMAND B107	
In-wall Inspection	John Borns	Partial	Wednesday, April 16, 2014
Partial Correction 1 MISC		OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT FIRE COMMAND B107 INCLUDING RE-WORKED EAST WALL	

Comments: