

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122456, Building Permit - Commercial
Address: 1611 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Partial	Thursday, April 17, 2014

Partial Correction
1 MISC

BUILDING 4: OK TO COVER WALL & CEILING FRAMING AND CONCEALED SYSTEMS AT: UNITS 400-415;

WIRING AT ALL ELECTRICAL BOXES TO BE APPROVED BEFORE DEVICES ARE INSTALLED. ENSURE ALL METALLIC BOXES ARE BONDED AND EQUIPMENT GROUNDING CONDUCTORS ARE CONNECTED WITH WIRE NUTS OR CRIMP CONNECTORS.

Partial Correction
2

*UNITS 416-419, IN WALL AT KITCHEN AREA AND BATHROOMS APPROVED TO COVER

Comments: