

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140090, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Thursday, April 17, 2014

Partial Correction  
1 MISC

1A029A & 1A029B CHEF'S OFFICE AND DIETARY ROOM: AT E WALL ONE LAYER 5/8" TYPE X GWB TO STRUCURAL DECK TAPED, MUDDED AND FIRE-SEALED; AT N, W, S WALLS ONE LAYER 5/8" TYPE X GWB TO LID ELEVATION PER PR#1 OK TO TAPE, MUD, AND FIRE-SEAL; FRAMING AND LINER BOARD AT RATED LIDS ABOVE 1A029A & 1A029B CHEF'S OFFICE AND DIETARY ROOM; ONE LAYER 5/8" TYPE X GWB AT WALL TO STRUCTURAL DECK ABOVE DOOR (1A029B);

Partial Correction  
2 MISC

1A029 DRY STORAGE: ALL PERIMETER WALLS BOTH FACES PER REV. 1 ONE LAYER 5/8" TYPE X GWB OK TO TAPE, MUD & FIRE-SEAL; NE WALL OF 1A029A SEALED TO COLUMN 5/C

Partial Correction  
3

LID OF DIETARY ROOM SCREW PATTERN APPROVED.  
HALL SIDE OF STORAGE SCREW APPROVED.

**Comments:**