

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Monday, April 21, 2014

Partial Correction
1 MISC

MAJORITY OF GREASE DUCT IN PLACE AND LIGHT-TESTED IN PLACE AS WELL AS POSSIBLE (SHOP WELDS WERE NOT LIGHT-TESTED ON FLOOR). ONE LOCATION FOUND WITH OPENINGS; WELDED SHUT ON THE SPOT; **SHOP WELDS ON VERTICAL DROPS LIGHT-TESTED ON FLOOR...FIELD WELDS AT JOINTS TO BE TESTED WHEN READY;**

Comments: