

## PLAN REVIEW CONDITIONS

April 24, 2014

PULSE DESIGN GROUP  
8207 MELROSE DRIVE, SUITE 145  
LENEXA, KS 66214

Permit No: PRCOM20140598  
Project Title: SAINT LUKES MEDICAL OFFICE EXPANSION  
Project Address: 20 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086  
Parcel Number: 52440044000000000  
Location: SAINT LUKES HOSPITAL OF LEES SUMMIT LOTS 1 & 2---LOT 1  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group: INSTITUTIONAL, SUPERVISED ENVIRONMENT  
Description: MEDICAL OFFICE EXPANSION

### ***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved**

#### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved with Conditions**

1. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans if work is required

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans for any modifications to the system

#### **Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of MEP contractors.

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***