

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Monday, April 28, 2014
Above Ceiling Inspection	John Borns	Passed	Monday, April 28, 2014

Comments:

**OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @
FIRE COMMAND CENTER AFTER ONE ABANDONED MC BOX CONNECTOR IS
REPLACED WITH BLUNDER PLUG.**

**OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING AT 5TH FLOOR
EXTERIOR WALL ON (D) FROM (2) TO (3).**