



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

April 28, 2014

REORGANIZED SCHOOL DIST NO 7  
600 SE MILLER  
LEES SUMMIT, MO 64063--4297

Permit No: PRCOM20140591  
Project Title: LSR7 STANSBERYY LEADERSHIP CENTER BUILDING SECURITY UPGRADES  
Project Address: 301 NE TUDOR RD, LEES SUMMIT, MO 64086  
Parcel Number: 52900043500000000  
Location: LEES SUMMIT HIGH SCHOOL ON DOUGLAS STREET PT LOT 1 DAF: BEG NW COR SD LOT 1 TH S 87 DEG E 1485' MOL TH S 1 DEG W 1520' MOL TH N 87 DEG W 1494.41' TH N 1 DEG E 1032.45' TH N 1 DEG E 479.98' TO POB  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group: EDUCATIONAL  
Description: BUILDING SECURITY UPGRADES

*The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.*

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Building Plan Review**                      **Reviewed By: Joe Frogge**                      **Approved with Conditions**

**Fire Plan Review**                      **Reviewed By: Brian Austerman**                      **Approved with Conditions**

1. Extend sprinkler coverage to include vestibule. Submit as-built drawings for the additional sprinkler coverage

2. Extend the emergency egress lighting for the exterior of the vestibule

**Fire Plan Review**                      **Reviewed By: Brian Austerman**                      **Approved with Conditions**

1. Extend sprinkler coverage to include vestibule. Submit as-built drawings for the additional sprinkler coverage

2. Extend the emergency egress lighting for the exterior of the vestibule

3. Extend standpipes to the new entrance, if standpipes are present in the existing vestibule

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***