

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20131163, Building Permit - Residential

Address: 610 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081610 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Borns	Failed	Tuesday, April 29, 2014

Corrective Action Required

2 MISC

UNITS A & B: STUD SHOES REQUIRED AT WASHER DRAIN PENETRATION OF STUDS

Corrective Action Required

3 MISC

UNITS A & B: CARIFICATION RQUIRED RE CONCRETE CONTACT WITH UN-TREATED LUMBER.

Corrective Action Required

4 MISC

UNIT B: FIRE-BLOCKING INCOMPLETE AT TOP PLATES AT FURNACE ROOM

**Comments:**