

Temporary Certificate of Occupancy

Permit #: PRCOM20131937
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Tuesday, April 29, 2014
Inspected By: John Borns
Expiration Date: 5/8/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, April 29, 2014

Corrective Action Required:

1 MISC PLANNING DEPARTMENT INSPECTION PENDING COMPLETION OF SITEWORK

Corrective Action Required:

2 MISC ROOFTOP INSPECTION:
- PROTECT LOW VOLTAGE WIRING @ EAST WALL
- CLEAR/CLEAN ROOF SURFACE -- ALL MATERIAL