

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122456, Building Permit - Commercial
Address: 1611 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Wednesday, April 30, 2014

Comments: OK TO INSTALL RECEPTACLES AND SWITCHES IF WHEN INSTALLING DEVICES ALL EQUIPMENT GROUND SPLICES ARE CHECKED AND WIRE-NUTTED OR CRIMPED. PER NEC 250.140 COPPER BONDING PIGTAILS WILL NOT BE INSTALLED AT 220V BOXES AND DOUBLE-LUGGED AT DEVICES.