

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140449, Building Permit - Commercial
Address: 1164 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Tuesday, May 06, 2014

Corrective Action Required
2 MISC

NEC 334-10 SECURING / SUPPORT OF MC ELECTRICAL CABLE: SECURE WITHIN 12" OF BOXES AND SUPPORT AT 6' MAX INTERVALS THEREAFTER. NOT TO BE ATTACHED TO CEILING SUPPORT WIRES.

Corrective Action Required
3 MISC

NEC 314.16; IRC E3905.13 ELECTRICAL BOX FILL: CHECK ALL ELECTRICAL BOXES FOR BOX FILL RESTRICTIONS -- CORRECT AS NEEDED.

Comments: