

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140449, Building Permit - Commercial
Address: 1164 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, May 07, 2014

Corrective Action Required
3 MISC

AT REAR WALL ABOVE 12"x12" ELECT JUNCTION BOX SOME MC CABLES ENTERING 4x4 BOX ARE NOT SECURED INSIDE "DOUBLE SLAMMERS". LEAVE OUT ONE TILE FOR RE-INSPECTION. OK TO PLACE CEILING TILE EXCEPT AT THIS LOCATION.

Comments: