

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20131167, Building Permit - Residential

Address: 622 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Failed	Wednesday, May 07, 2014

Partial Correction

1 MISC

Corrective Action Required

2 MISC

FOLLOWING UIT(S) OK FOR USE AND OCCUPANCY: UNIT "C";

UNIT B:

- 1) PROVIDE MAINTENANCE CLEARANCE AROUND HOSE BIB AT FRONT OF UNIT
- 2) INSTALL VACUUM BREAKER AT HOSE BIB IN BASEMENT AT WATER SERVICE ENTRY
- 3) SECURE PIPE POST BASE PLATES TO BASEMENT FLOOR SLAB

Comments: