

# Certificate of Occupancy

---

**Permit #:** PRCOM20140449  
**Address:** 1164 NE DOUGLAS ST, LEES SUMMIT, MO 64086  
**Inspected On:** Friday, May 09, 2014  
**Inspected By:** John Borns

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection -</b> John Borns Codes Commercial	Full C of O	Friday, May 09, 2014	

**Comments:** HAVE PLUMBER COMPLETE SECURING OF TPR BLOW-OFF PIPE TO FLOOR UNDER SINK IN RESTROOM. AFFIX "NO SMOKING" STICKER TO FRONT DOOR OR GLASS BESIDE DOOR.