

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140833, Building Permit - Commercial
Address: 809 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mark Harding	Failed	Friday, May 09, 2014

Corrective Action Required

- | | | |
|---|------|---|
| 1 | MISC | 1. SECURE SE CABLE WITH IN 12" OF PANEL
2. SECURE ROMEX 4.5 FT O.C.
3. SEPERATE WIRES IN RAN NEXT TO ROMEX IN CEILING
4. OPEN -OVERFILLED BOXES- SOUTH EAST SIDE OF ATTIC.
5. SECURE ROMEX ENDS-INTO BOXES- BASEMENT.
6. ADDRESS THE PANEL
7. CARPET AND WOOD SHALL BE CUT AWAY FROM OPEING AND SPARK
ARRESTER SHALL BE INSTALLED
BUILDING SHALL NOT BE OCCUPIED. |
|---|------|---|

Comments: