

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140507, Building Permit - Commercial
Address: 304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mark Harding	Partial	Wednesday, May 14, 2014

Corrective Action Required

1	MISC	WILLIAM WILL HAVE A PLAN WE CAN INITIAL- -31-LIGHT POLES -4 pole base northeast side 4#6 BARS- 8' PIER 5IN-3OUT-TIES 18"O.C.
---	------	---

Comments: