

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140833, Building Permit - Commercial
Address: 809 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mark Harding	Partial	Wednesday, May 14, 2014

Corrective Action Required
1 MISC

3. REPLACE OR INSTALL CONDUIT CEILING OF BSMT NM OPEN TO CEILING BOX
7. CARPET AND WOOD SHALL BE CUT AWAY FROM OPEING AND SPARK ARRESTER SHALL BE INSTALLED
BUILDING SHALL NOT BE OCCUPIED.

OK TO RELEASE SERVICE

Comments: