

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140442, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:300, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Thursday, May 15, 2014

Corrective Action Required

1	MISC	CHECK ALL JAMB STUDS; SCREW ALL TO BASE TRACK.
---	------	--

Corrective Action Required

2	MISC	FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS AT FLOOR SLAB.
---	------	---

Corrective Action Required

3	MISC	CLOMplete FRAMING & BLOCKING FOR 42", 36", AND 18" GRAB BARS IN 3D314 AND 3D318.
---	------	--

Corrective Action Required

4	MISC	IPC - PROTECTION OF COPPER PIPING AT PENETRATION OF STEEL FRAMING MEMBERS: INSTALL GROMMETS OR OTHER APPROVED PROTECTION FROM SHARP EDGES & DISSIMILAR METAL.
---	------	---

Corrective Action Required

5	MISC	RE-FRAMING AT 3D316 NOT COMPLETED FOR INSPECTION.
---	------	---

Comments: