

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132456, Building Permit - Commercial
Address: 1195 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Passed	Friday, May 16, 2014

Comments: UNDERGROUND ELECTRICAL CONDUIT WAS BURIED FROM METER TO J.B./RECEPTACLES @ SEASONAL TREE WITHOUT INSPECTION AND APPROVAL AND IS NOT APPROVED FOR USE. E.C. HAS REMOVED CABLE FROM BURIED CONDUIT AND DISCONNECTED CONDUIT AT TEMPORARY SERVICE POLE. SERVICE EQUIPMENT IS APPROVED FOR TEMPORARY USE ONLY.