

Temporary Certificate of Occupancy

Permit #: PRCOM20122456
Address: 1611 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Friday, May 16, 2014
Inspected By: John Borns
Expiration Date: 6/5/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, May 16, 2014

Corrective Action Required:

1 MISC CORRIDOR NOT READY FOR FINAL INSPECTION.

Corrective Action Required:

3 MISC Sec. 7-1408.1. Hinges.

Hinges for exterior swinging doors shall comply with the following:
A.

At least two (2) wood screws, three (3) inches in length, penetrating at least one inch into wall structure shall be used. Solid wood fillers or shims shall be used to eliminate any space between the wall structure and door frame behind each hinge.

Exception: Hinges within a door frame installed directly adjacent to a sidelight.

B.

Hinges for out-swinging doors shall be equipped with mechanical

interlock to preclude the removal of the door from the exterior.