

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140442, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, Unit:300, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Friday, May 16, 2014

Corrective Action Required

1	MISC	JAMB STUDS NOT SCREWED TO BASE TRACK AT 3D312B; DO NOT DRYWALL THIS SPACE.
---	------	--

Partial Correction

3	MISC	BLOCKING REQUIRED FOR 42", 36", AND 18" GRAB BARS IN 3D314 AND 3D318.
---	------	---

Corrective Action Required

5	MISC	FRAMING OF BULKHEADS AND FACIAS AT 3D316 NOT APPROVED TO COVER.
---	------	---

Corrective Action Required

6	MISC	<b>OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT ALL SPACES EXCEPT 3D312B AND 3D316.</b>
---	------	---

**Comments:**