

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20140176  
**Address:** 880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086  
**Inspected On:** Monday, May 19, 2014  
**Inspected By:** John Borns  
**Expiration Date:** 5/29/2014 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Monday, May 19, 2014

**Corrective Action Required:**

6 MISC LOOSE ELECT RECEPTS: [100] N.E.

**Corrective Action Required:**

9 MISC DESIGNATE ELECTRICAL PANELS AT PANEL FRONTS.

24 POSTION ELECT PANEL HAS 42 POSTION PANEL SCHEDULE.