

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140310, Building Permit - Commercial
Address: 795 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Khanh Nguyen	Failed	Monday, May 19, 2014

Corrective Action Required

1	MISC	*LIGHT TESTED DUCTS ON THE GROUND. COMPLETE THE WHOLE DUCT INSTALLTION AND FIRE-WRAPPING. CHECK AT ABOVE-CEILING INSPECTION
		-THE TYPE I HOOD EXHAUST OPENING MUST BE MINIMUM 40" ABOVE THE ROOF SURFACE

Comments: