

FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

May 21, 2014

PHOENIX CONSTRUCTION, INC 1305 HOLLY CT LIBERTY, MO 64068

Permit No: PRCOM20141292

Project Title: KANSAS CITY SALT MINE

Project Address: 3680 NE AKIN DR, Unit:112, LEES SUMMIT, MO 64064

Parcel Number: 43810020700000000

Location: CHAPEL RIDGE BUSINESS PARK, LOTS 10-18 & TRACTS H THRU K---LOT 17

Type of Work: NEW TENANT FINISH

Occupancy Group: BUSINESS

Description: TENANT FINISH FOR MASSAGE THERAPY

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Joe Frogge Pending

Fire Plan Review Reviewed By: Brian Austerman Approved with Conditions

- 1. Add an exterior emergency light at the rear entrance, if not existing
- 2. 2012 IFC 906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a 2A10B:C extinguisher (5 lb)

3. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans for any alterations made to the system

4. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4.

Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans if modifications to interior notification are required

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.