

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140191, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---------------------------|------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| In-wall Inspection | John Borns | Partial | Thursday, May 22, 2014 |

Corrective Action Required

| | | |
|---|------|---|
| 1 | MISC | SOUTH WALL @ 56' EAST END EXPANSION SPACE: NEC 300-11, 330.30 & 334-10 INSTALLATION OF MC ELECTRICAL CABLE: NOT SECURELY FASTENED WITHIN 12" OF ENTRY TO BOXES. DO NOT COVER. |
|---|------|---|

**Comments: SOUTH WALL COVERED WITHOUT APPROVAL.
WALL IN-FILL @ EAST WALL NE CORNER OK TO COVER WHEN READY.**